



CERTIFICATE OF ACCREDITATION

This is to attest that

BUTLER ENGINEERING (ME)


UNIT 710 APRICOT TOWER, DUBAI SILICON OASIS, NADD HESSA
DUBAI, UNITED ARAB EMIRATES

Special Inspection Agency SIA-182 (Type A)

has met the requirements of the applicable provisions of AC291, *IAS Accreditation Criteria for Special Inspection Agencies*, has demonstrated compliance with ISO/IEC Standard 17020:2012, *Conformity assessment - Requirements for the operation of various types of bodies performing inspection* and *UAE Fire & Life Safety Code of Practice 2018 Edition*. This organization is accredited to provide the services specified in the scope of accreditation.

Valid thru June 1, 2023

Effective Date December 14, 2021



Raj Nathan
President

Visit www.iasonline.org for current accreditation information.

SCOPE OF ACCREDITATION

International Accreditation Service, Inc.

3060 Saturn Street, Suite 100, Brea, California 92821, U.S.A. | www.iasonline.org

BUTLER ENGINEERING (ME)

www.butlerme.com

Contact Name Fahad Liaqat

Contact Phone +971-554585419

Contact Name Huma Zaidi

Contact Name Joanna Encarnacion

Accredited to ISO/IEC 17020:2012

Effective Date December 14, 2021

Section 5 of IAS AC291 is used along with *UAE Fire & Life Safety Code of Practice 2018 Edition*.

Field and Types of Inspection	Inspection Procedures and Reference Documents
Management System Documentation: Butler Engineering (ME)-BE-01-(Level 1), R10 (20/10/2021); QSP-L2-R10 of 2021 and BE-03-IP-R10 of 2021 for UAE Fire & Life Safety Code of Practice 2018 Edition and other applicable Regulations	
Through penetration Firestop system	Butler Engineering ME QMS (Level 2) QSP-L2-2021; 2018 International Building Code Sections 1705.16 and 1705.16.1; ASTM E814 and E2174; UL 1479 and UAE Fire & Life Safety Code of Practice 2018
Fire Resistive Joint System, Membrane-penetration, Perimeter fire barriers	Butler Engineering ME QMS (Level 2) QSP-L2-2021; 2018 International Building Code Sections 1705.16 and 1705.16.2; ASTM E1966 and E2393; UL 2079 and UAE Fire & Life Safety Code of Practice 2018
Building Perimeter Fire Barriers	Butler Engineering ME QMS (Level 2) QSP- L2-2021; 2018 International Building Code Sections 1705.16 and 1704.16.2; ASTM E2307 and E2393; NFPA 285 and UAE Fire & Life Safety Code of Practice 2018